


RAPPORT

Björn Karlsson

Fire Risk Index Method – Multistorey Apartment Buildings

FRIM-MAB

Version 2.0



Trätek

INSTITUTET FÖR TRÄTEKNISK FORSKNING

Björn Karlsson

**FIRE RISK INDEX METHOD – MULTISTOREY APARTMENT BUILDINGS
FRIM-MAB**

Version 2.0

Trätek, Rapport P 0212053

ISSN 1102 – 1071

ISRN TRÅTEK – R – – 02/053 – – SE

Keywords

*fire safety
multistorey buildings
residential buildings
risk analysis
risk assessment
timber-frame structures
wood products*

Stockholm December 2002

LIST OF CONTENTS

FÖRORD.....	1
SVENSK SAMMANFATTNING	2
PREFACE	3
ENGLISH SUMMARY	4
BACKGROUND.....	5
USING THE METHOD	6
POLICY, OBJECTIVES AND A LIST OF PARAMETERS	9
P₁ LININGS IN APARTMENT	11
P₂ SUPPRESSION SYSTEM	12
P₃ FIRE SERVICE	13
P₄ COMPARTMENTATION	14
P₅ STRUCTURE - SEPARATING	15
P₆ DOORS	17
P₇ WINDOWS.....	18
P₈ FACADES	19
P₉ ATTIC	20
P₁₀ ADJACENT BUILDINGS	21
P₁₁ SMOKE CONTROL SYSTEM.....	22
P₁₂ DETECTION SYSTEM.....	23
P₁₃ SIGNAL SYSTEM	24
P₁₄ ESCAPE ROUTES.....	25
P₁₅ STRUCTURE - LOAD-BEARING	27
P₁₆ MAINTENANCE AND INFORMATION	28
P₁₇ VENTILATION SYSTEM	29
PARAMETER SUMMARY TABLE	30
REFERENCES.....	31

FÖRORD

De senaste åren har ett antal flervåningshus med trästomme byggts i de nordiska länderna. Sådana konstruktioner har tidigare inte tillåtits av byggreglerna, till stor del på grund av brandrisken. De nordiska länderna har därför samarbetat inom Nordic Wood för att ta fram konstruktionslösningar som avsevärt minskar brandriskerna i hus med trästomme. En nordisk handbok "Brandsäkra trähus - kunskapsöversikt och vägledning" publicerades hösten 1999 och gavs ut i en ny betydligt utvidgad version hösten 2002.

Det är svårt att jämföra brandriskerna i hus av obrännbar stomme med brandrisker i hus av trästomme. Dessa risker beror på en mängd olika faktorer. Det mest praktiska angreppssättet är därför att utveckla en så kallad indexmetod, som kan användas för att rangordna brandsäkerheten i olika byggnader.

Indexmetoden har utvecklats vid Lunds Tekniska Högskola, avdelningen för Brandteknik. En första version presenterades 1998 av Sven-Erik Magnusson och Tomas Rantatalo. Metoden har därefter vidareutvecklats av Björn Karlsson, nu verksam vid Iceland Fire Authority, i nära samverkan med en nordisk projektgrupp och en nordisk sk Delphi-panel. Arbetet ingår i det nordiska projektet Brandsäkra trähus som stöds av Nordic Wood-programmet.

Nordic Wood är den nordiska träindustrins FoU-program med målet att öka träanvändningen. Programmet finansieras av den nordiska träindustrin, Nordisk Industrifond och de nationella FoU-organen: Erhvervsfremmestyrelsen i Danmark, TEKES i Finland, Islands forskningsråd, Norges Forskningsråd och VINNOVA/NUTEK i Sverige. I programmet ingår ett femtiotal projekt.

Arbetet med Indexmetoden har bedrivits i två faser. Den andra fasen har finansierats av SBUF - Svenska Byggbranschens Utvecklingsfond, Nordisk Industrifond, Nordtest och VINNOVA.

Vi tackar varmt för detta stöd. Tack också till den nordiska projektgruppen, Delphi-panelen samt övriga som bidragit till utvecklingen av Indexmetoden. Vi hoppas att den ska bidra till ett brandsäkert och ökat trähusbyggande.

Stockholm december 2002.

Birgit Östman
Projektkoordinator

Nordisk styrgrupp

Vidar Sjödin, Brandforsk, ordf. (SE)
Henrik Hviid Pedersen, Lilleheden Advance (DK)
Bjarne Lund Johansen, Træbranchens Oplysningsråd (DK)
Charlotte Micheelsen, By- og Boligministeriet (DK)
Keijo Kolu, Schauman Wood (FI)
Olavi Lilja, Miljöministeriet (FI)
Pekka Nurro, Woodfocus (FI)
Wiran Bjørkmann, Statens bygningstekniske etat (NO)
Lars Grøtta, Moelven (NO)
Anders Johansson, Boverket (SE)
Rosemarie Lindberg, Svenskt Trä (SE)
Anders Paulsson, Bjerking (SE)

SVENSK SAMMANFATTNING

En ny indexmetod för att värdera brandrisker i bostadshus i flera våningar har tagits fram.

Indexmetoden bygger på att strukturen för brandsäkerheten i en byggnad kan ordnas i ett antal nivåer. Överst ligger den *policy* som gäller, sedan specificeras *målen*, på nästa nivå *strategierna* och sist ett stort antal *parametrar*. Parametrarna delas in i *underparametrar* som är kvantifierbara, organiseras i *beslutstabeller* och ges ett mätbart *betyg*. När indexmetodens struktur är fastställd ges målen, strategierna och parametrarna *vikter*.

Indexmetodens struktur och de vikter som tilldelas målen, strategierna och parametrarna har bestämts genom s k Delphi-metod, en välprövad metod för att strukturera en expertgrupps åsikter. Fem experter deltog (med bakgrund i dimensionering, provning, brandförsvar, försäkring och forskning) från varje nordiskt land (Danmark, Finland, Norge och Sverige) d v s totalt 20 experter.

Genom matrismultiplikation av betygen och vikterna fås ett relativt mått på vikten av varje parameter. Summan av de viktade betygen ger ett enda indexvärde för det aktuella byggobjektet. Detta värde kan sedan jämföras med ett indexvärde för andra byggnader eller användas för att jämföra olika brandskyddsåtgärder. Förutsättningen är givetvis att byggnormens grundkrav är uppfyllda.

För att värdera den framtagna indexmetoden utfördes samtidigt en kvantitativ riskanalys (QRA) av fyra flervåningshus i trästomme, nyligen uppförda i de nordiska länderna. Både indexmetoden och den kvantitativa riskanalysen användes för att rangordna byggnaderna vad gäller brandsäkerhet. Jämförelsen visar ett relativt samstämmigt resultat med tanke på att metoderna är väldigt olika.

Indexmetoden kan användas direkt för alla bostadshus i flera våningar, utvärderingen kräver cirka en dags arbete samt att utvärderaren är ingenjör eller har en bakgrund inom brandområdet. En kvantitativ riskanalys kräver å andra sidan att varje byggnad individuellt studeras och att ett flertal antaganden görs i varje fall för sig, om t.ex. byggnaden, de boende och brandkårens agerande. En sådan analys kräver i storleksordningen en till två veckors arbete och utvärderaren måste vara specialist inom området brandteknik och riskvärdering.

Detta dokument beskriver indexmetoden på engelska. Det innehåller beslutstabeller och hjälptexter som resulterar i ett s k riskindex för brandriskerna i ett flervånings bostadshus. Dokumentet beskriver kortfattat metodens bakgrund och arbetsgången samt kommentarer från användare.

Version 2.0 innehåller fler hjälptexter än den tidigare versionen 1.2, vilket är ett resultatet av att metoden analyserats och tillämpats på fler byggnader.

Indexmetoden finns även tillgänglig på Internet, www.brand.lth.se/frim-mab

En svensk kortversion av indexmetoden finns i TräteK Kontenta 0009024, som givits ut i en ny reviderad version år 2002.

PREFACE

In the last few years a number of multistorey apartment buildings have been constructed in the Nordic countries using timber as load bearing material. Such constructions have earlier not been allowed by the authorities, mainly due to the fire risk. The Nordic countries have therefore co-operated for some years, within the Nordic Wood program, with the aim of developing construction methodologies that seriously diminish the fire risk in timber-frame multistorey buildings. As a part of this work, a Nordic handbook on fire safety design of timber buildings was published in 1999 and an extended version in 2002.

It is however difficult to compare the fire risk in a building of non-combustible frame and a timber-frame building. These risks are based on a large number of different factors. The most practical way to rationally deal with this is to develop a so-called index method that can be used to rank different buildings with respect to fire risk.

The Index Method has been developed at Lund University, Department for Fire Safety Engineering. A first version was presented 1998 by Sven-Erik Magnusson and Tomas Rantatalo. The method has then been further developed by Björn Karlsson, now at Iceland Fire Authority, in close cooperation with a Nordic project team and a Nordic Delphi-panel. The work is part of the Nordic project Fire safe wooden buildings and supported by the Nordic Wood programme.

Nordic Wood is a R&D programme with the aim to increase the use of wood products. The programme is financed by the Nordic Timber industries, the Nordic Industrial Fund and national R&D funds. About fifty projects are run in the Nordic Wood programme.

The development of the Index method has run in two phases. The second phase has been financed by the Development Fund of the Swedish Construction Industry SBUF, the Nordic Industrial Fund NI, Nordtest and the Swedish Agency for Innovation Systems VINNOVA.

The financial support is kindly acknowledged. Thanks also to the Nordic project team, the Nordic Delphi-panel and for other contributions to the Index method. We hope that the method will contribute to a fire safe and increased use of timber in buildings.

Stockholm December 2002.

Birgit Östman
Project coordinator

ENGLISH SUMMARY

A new Index method for the assessment of fire risks in multistorey apartment buildings has been developed.

The Index method is based on a hierarchy structure for the fire safety in a building. The highest level is the *policy*, then the *objectives*, at next level the *strategies* and finally several *parameters*. The parameters are subdivided into quantitative *sub parameters*, organised in *decision tables* and given a *grade*. When the structure is fixed, the objectives, strategies and parameters are given *weights*.

The Index method was developed together with a Nordic project group, using a so-called Delphi panel for fine-tuning the method and defining the weights. The Delphi panel was made up of 20 Nordic experts who work with fire safety in various areas (consultancy, fire brigade, fire testing, fire research and insurance).

The grades and weights are multiplied giving a relative value for each parameter. The sum of these weighted grades results in a single index value for the whole building which can be used to compare with index values for other buildings or different fire safety measures. Basic requirements in the building law must of course be fulfilled.

To evaluate the index method, a quantitative risk analysis (QRA) was carried out on four multistorey timber-frame buildings, recently constructed in four Nordic countries. Both the index method and the quantitative risk analysis were used to rank the buildings with respect to fire risk. The comparison showed a reasonably good agreement, keeping in mind that the two methods are very different in nature.

The index method can be used directly on all multistorey apartment buildings. To derive a fire risk index takes roughly one days work and demands that the user is an engineer or has some background in fire safety. A quantitative risk analysis, on the other hand, demands that each building be studied separately and that different assumptions be made in each case on, for example, the building, the occupants and fire brigade tactics. Such an analysis may take a number of weeks in each case and demands that the analyst is a specialist in fire safety and risk analysis.

This document contains the decision-making tables that result in an index value for the fire risk in a multistorey apartment building. The document gives a summary description of the index method, gives a short description of the development process, describes how to use the method and discusses the comments received from users.

Version 2.0 contains more comments from users than version 1.2 as a result of further analysis and applications to more buildings.

The Index method is also available at Internet, www.brand.lth.se/frim-mab

BACKGROUND

During the last few years the trend in a great part of the world has been to introduce performance-based building regulations instead of the detailed regulations used earlier. The new regulations, based on functional requirements, have also been accepted in the Nordic countries. The new possibilities have opened the way for new design solutions, e.g. new applications for timber-structures.

From a fire safety point of view a wider use of timber-structures is of course of considerable interest. It is, however, necessary to verify that the fire safety, with respect to both life safety and property protection, is as high in timber-frame buildings as in other types of buildings. To allow a comparison it has been observed that there is a need of developing a new fire risk assessment technique. Such a technique has to answer questions from society on the fire safety in a building. It has to be possible to compare the level of safety in a specific building to other buildings and to an acceptable risk. The level of fire safety in a building depends on a great number of factors and there is a need of systemising the way of identifying, analysing and evaluating these.

As a result of these needs, the research program Nordic Wood has supported the development of a risk index method to assess the level of fire risk in multistorey apartment buildings. Nordic Wood is a research- and development program initiated by the Nordic Industrial Fund and the Nordic wood industry. The main aim of the program is to consolidate the position of wood as a construction material, e.g. in multi-storey buildings. The Nordic Wood project "Fire-safe Wooden Houses" has focused on the fire safety problems, which always have been connected to timber-frame buildings. The state-of-art knowledge with respect to the use of wood as a construction material has, however, grown rapidly through the last decade. As a part of the research work, a Nordic handbook on fire safety design of timber buildings was published in 1999. An extended version was published in 2002 /1/.

For the above reasons, industry and authorities found that it was necessary to develop a simple technique to evaluate the fire risk in multistorey apartment buildings. The only method that is simple to use and at the same time takes account of the many different objectives and parameters that constitute building fire safety is an index method of the type that is presented here. The method was developed by a Nordic project group, using a so-called Delphi panel for fine-tuning the method. The Delphi panel was made up of 20 Nordic experts who work with fire safety in various areas (consultancy, fire brigade, fire testing, fire research and insurance). The development process is described in detail in two reports /2, 3/.

To evaluate the index method, a quantitative risk analysis (QRA) was carried out on four multistorey timber-frame buildings, recently constructed in four Nordic countries. Both the index method and the quantitative risk analysis were used to rank the buildings with respect to fire risk. The comparison showed a reasonably good agreement, keeping in mind that the two methods are very different in nature. The comparison is described in a separate report /4/.

The index method has recently been analysed and requirement levels according to building codes in the Nordic countries have been determined /5/. A repeatability study has also been performed /6/. As a result this version 2.0 of the index method is published.

The advantage of using an index method for fire risk ranking is that the ranking takes little time and can be carried out by an engineer or a fire safety professional. All other rational methods for this purpose would take much longer time and must be carried out by specialists in fire safety design and risk analysis.

USING THE METHOD

This document first describes the policy, objectives and strategies of the fire safety system used and then gives a list of the parameters. Subsequently, each parameter is described, sometimes using sub-parameters and decision tables. The user works through each parameter until all parameters have been given a grade. On the last page the grades are entered in a table and multiplied by weights. These weighted grades are then summed up and result in an index value, a risk index.

During the development and the evaluation of the index method, professionals who have tried out the method or have investigated its background have raised a number of questions. Many of the comments have been included as "Comments from users" for each parameter.

One general comment was that some parameters allow that alternatives lesser than the minimum requirements according to the building regulations be chosen. For example, Parameter 1 (Lining materials) allows that a plastic material be chosen as a lining material, which is not at all acceptable in the building regulations in the Nordic countries. Such choices are, however, made possible in the index method, since sometimes a combination of choices can be compensated for by making other parameters much more safe. Nevertheless, **a designer must of course always adhere to the building regulations.**

The user must therefore both aim for a reasonably high index grade (a safe building), but at the same time make certain that the minimum requirements according to the building law are met. Sometimes authorities allow lesser requirements than the minimum to be used, given that this is compensated by higher requirements in other parameters. For example, installing a sprinkler can lead the authorities to agree on lesser than minimum requirements for distance between buildings (or some other parameter).

However, minimum requirements differ considerably within the Nordic countries and there is a considerable difference in how the authorities allow or disallow lesser requirements and how these are compensated for by higher requirements in other parameters. In using the index method, the engineer is encouraged to have a continuous and open dialogue with the authorities.

Limitations

Any engineering method, in any engineering discipline, can be misused and so can the Index method presented here. It is quite possible to achieve a good index rating by giving some parameters a very bad rating and other parameters extremely good rating. For example, an engineer may give full marks for detection (parameter P_{12}) but zero marks for a signal system (parameter P_{13}), indicating a design where fires are detected but no warning signal is given. In spite of the good index rating, the resulting building design may be totally unacceptable or absurd from a fire safety point of view. But this is only possible if the engineer really wishes to misuse the method. The building design and the use of the method must therefore be based on common sense, as is true for most methods in all engineering disciplines.

It is important to note that the index method does not replace building regulations and that it is assumed that the designer ensures that the building fulfils all mayor demands made in the building regulations. As an example, an engineer can not use the method to "prove" that a very combustible lining material can be used in escape routes (giving a low grade for P_1 , Lining materials) by simply increasing the the grade for some other parameter, thereby achieving an acceptable overall index rating.

Also, it is important to note that the index method is **not an engineering design method**. For example, if a designer wishes to reduce the minimum separation distance from other buildings, as prescribed in the building regulation, radiation calculations and a special window glass may e g be used in order to "prove" that the separation distance can be reduced. The designer can not use the index method as a design method (getting a low value for the adjacent buildings parameter, P_{10} , and increasing the value for some other parameter), but must use proper design methods.

Therefore, the risk index is *not* a measure of the absolute fire safety level, but a rough indicator of whether the building is safer than other buildings or not. The method also very well illustrates different ways of enhancing the fire safety level and can be used to roughly compare different options. Receiving a risk index lower than the acceptable risk level is *not* a guarantee that the building fulfils the current building regulations. The method is only one of many tools that an engineer can use to assist in designing a building against fire.


Internet version

The index method is also available on Internet at <http://www.brand.lth.se/frim-mab>. This web site contains a simple computer program for automatic calculation of the Risk index from input data for a building.

The development of the method is by no means over; in fact it is only now starting. New developments will be discussed on the web site given above. Users who have comments on the method are asked to contact Birgit Östman at Trätek or give comments through the web site.

A short version of the Index method is available also in Swedish /7/.

The overall structure of the Index method



POLICY, OBJECTIVES AND A LIST OF PARAMETERS

Policy:

Provide acceptable fire safety level in multistorey apartment buildings

Definition: Multistorey apartment buildings shall be designed in a way that ensures sufficient life safety and property protection in accordance with the objectives listed below.

Objectives:

O₁ Provide life safety

Definition: Life safety of occupants in the compartment of origin, the rest of the building, outside and in adjacent buildings and life safety of fire fighters

O₂ Provide property protection

Definition: Protection of property in the compartment of origin, in the rest of the building, outside and in adjacent buildings

Strategies:

S₁ Control fire growth by active means

Definition: Controlling the fire growth by using active systems (suppression systems and smoke control systems) and the fire service.

S₂ Confine fire by construction

Definition: Provide structural stability, control the movement of fire through containment, use fire safe materials (linings and facade material). This has to do with passive systems or materials that are constantly in place.

S₃ Establish safe egress

Definition: Cause movement of occupants and provide movement means for occupants. This is done by designing detection systems, signal systems, by designing escape routes and by educating or training the occupants. In some cases the design of the escape route may involve action by the fire brigade (escape by ladder through window).

S₄ Establish safe rescue

Definition: Protect the lives and ensure safety of fire brigades personnel during rescue. This is done by providing structural stability and preventing rapid unexpected fire spread and collapse of building parts.

Parameters:

- P₁ Linings in apartment**
Definition Possibility of internal linings in an apartment to delay the ignition of the structure and to reduce fire growth
- P₂ Suppression system**
Definition: Equipment and systems for suppression of fires
- P₃ Fire service**
Definition: Possibility of fire services to save lives and to prevent further fire spread
- P₄ Compartmentation**
Definition: Extent to which building space is divided into fire compartments
- P₅ Structure - separating**
Definition: Fire resistance of building assemblies separating fire compartments
- P₆ Doors**
Definition: Fire and smoke separating function of doors between fire compartments
- P₇ Windows**
Definition: Windows and protection of windows, ie. factors affecting the possibility of fire spread through the openings
- P₈ Facade**
Definition: Facade material and factors affecting the possibility of fire spread along the facade
- P₉ Attic**
Definition: Prevention of fire spread to and in attic
- P₁₀ Adjacent buildings**
Definition: Minimum separation distance from other buildings
- P₁₁ Smoke control system**
Definition: Equipment and systems for limiting spread of toxic fire products
- P₁₂ Detection system**
Definition: Equipment and systems for detecting fires
- P₁₃ Signal system**
Definition: Equipment and systems for transmitting an alarm of fire
- P₁₄ Escape routes**
Definition: Adequacy and reliability of escape routes
- P₁₅ Structure - load-bearing**
Definition: Structural stability of the building when exposed to a fire
- P₁₆ Maintenance and information**
Definition: Inspection and maintenance of fire safety equipment, escape routes etc. and information to occupants in suppression and evacuation
- P₁₇ Ventilation system**
Definition: Extent to which the spread of smoke through the ventilation system is prevented.

P₁ LININGS IN APARTMENT

DEFINITION: Possibility of internal linings in an apartment to delay the ignition of the structure and to reduce fire growth

PARAMETER GRADE P₁:

This refers to the worst lining class (wall or ceiling) that is to be found in an apartment. (Excluding the small amounts allowed by building code.)

Typical products	LINING CLASS					GRADE P ₁
	Possible Euroclass *	DK	FIN	NO	SWE	
Stone, concrete	A1	A	1/I	In1	I	5
Gypsum boards	A2	A	1/I	In1	I	5
Best FR woods (impregnated)	B	A	1/I	In1	I	4
Textile wall cover on gypsum board	C		1/II 2/-	In2	II	3
Wood (untreated)	D	B	1/-	In2	III	2
Low density wood fibreboard	E	U	U	U	U	1
Some plastics	F	U	U	U	U	0

(Minimum grade = 0 and maximum grade = 5); * Only main class given

Resulting grade:

Comments from users: Inhabitants may change linings and different linings may be used in different parts of the building. The user must therefore give an engineering estimate of a reasonable lining class to reflect this.

P₂ SUPPRESSION SYSTEM

DEFINITION: Equipment and systems for suppression of fires

SUB-PARAMETERS:

P_{2a} Automatic sprinkler system

Type of sprinkler (N = no sprinkler, R = residential sprinkler, O = ordinary sprinkler)

Location of sprinkler (A = in apartment, E = in escape route, B = both in apartment and escape route)

SURVEY ITEMS	DECISION RULES						
Type of sprinkler	N	R	R	R	O	O	O
Location of sprinkler	-	A	E	B	A	E	B
GRADE P_{2a}	N	M	L	H	M	L	H

(N = no grade, L = low grade, M = medium grade and H = high grade)

P_{2b} Portable equipment

N	None
F	Extinguishing equipment on every floor
A	Extinguishing equipment in every apartment

PARAMETER GRADE P₂:

SUB-PARAMETERS	DECISION RULES											
P _{2a} Automatic sprinkler system	N	N	N	L	L	L	M	M	M	H	H	H
P _{2b} Portable equipment	N	F	A	N	F	A	N	F	A	N	F	A
GRADE P₂	0	0	1	1	1	2	4	4	4	5	5	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: Residential sprinkler systems can be different in different countries. A rough rule of thumb is that if the sprinkler operates on the ordinary water supply to the building, it is said to be a "residential sprinkler", but if it is fed from a specially designed water reservoir and has a relatively high capacity, it is termed an "ordinary sprinkler".

P₃ FIRE SERVICE

DEFINITION: Possibility of fire services to save lives and to prevent further fire spread

SUB-PARAMETERS:

P_{3a} Capability of responding fire service

CAPABILITY OF RESPONDING FIRE SERVICE	GRADE P _{3a}
No brigade available	0
Fire fighting capability only outside the building	1
Fire fighting capability but no smoke diving capability	2
Fire fighting and smoke diving capability	4
Simultaneous fire fighting, smoke diving and external rescue by ladders	5

(Minimum grade = 0 and maximum grade = 5)

P_{3b} Response time of fire service to the site

RESPONSE TIME (min)	GRADE P _{3b}
> 20	0
15 - 20	1
10 - 15	2
5 - 10	3
0 - 5	5

(Minimum grade = 0 and maximum grade = 5)

P_{3c} Accessibility and equipment (ie. number of windows (or balconies) that are accessible by the fire service ladder trucks)

ACCESSIBILITY AND EQUIPMENT	GRADE P _{3c}
Less than one window in each apartment accessible by fire service ladders	0
At least one window in each apartment accessible by fire service ladders	3
All windows accessible by fire service ladder	5

(Minimum grade = 0 and maximum grade = 5)

PARAMETER GRADE:

$$P_3 = (0.31 \times P_{3a} \text{ Capability} + 0.47 \times P_{3b} \text{ Response time} + 0.22 \times P_{3c} \text{ Accessibility and equipment})$$

Resulting grade:

Comments from users: No comments yet.

P₄ COMPARTMENTATION

DEFINITION: Extent to which building space is divided into fire compartments

PARAMETER GRADE P₄:

MAXIMUM AREA IN FIRE COMPARTMENT	GRADE P ₄
> 400 m ²	0
200 - 400 m ²	1
100 - 200 m ²	2
50 - 100 m ²	3
< 50 m ²	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: No comments yet

P₅ STRUCTURE - SEPARATING

DEFINITION: Fire resistance of building assemblies separating fire compartments

SUB-PARAMETERS:

P_{5a} Integrity and insulation

INTEGRITY AND INSULATION (EI)	GRADE P _{5a}
EI < EI 15	0
EI 15 ≤ EI < EI 30	1
EI 30 ≤ EI < EI 45	3
EI 45 ≤ EI < EI 60	4
EI ≥ EI60	5

(Minimum grade = 0 and maximum grade = 5)

P_{5b} Firestops at joints, intersections and concealed spaces

STRUCTURE AND FIRESTOP DESIGN	GRADE P _{5b}
Timber-frame structure with voids and no firestops	0
Ordinary design of joints, intersections and concealed spaces, without special consideration for fire safety.	1
Joints, intersections and concealed spaces are specially designed for preventing fire spread and deemed by engineers to have adequate performance.	2
Joints, intersections and concealed spaces have been tested and shown to have endurance in accordance with the EI of other parts of the construction.	3
Homogenous construction with no voids	5

(Minimum grade = 0 and maximum grade = 5)

P_{5c} Penetrations

Penetrations between separating fire compartments

PENETRATIONS	GRADE P _{5c}
Penetrations with no seals between fire compartments	0
Non-certified sealing systems between fire compartments	1
Certified sealing systems between fire compartments	2
Special installation shafts or ducts in an own fire compartment with certified sealing systems to other fire compartments	3
No penetrations between fire compartments	5

(Minimum grade = 0 and maximum grade = 5)

P_{5d} Combustibility

Combustible part of the separating construction

COMBUSTIBLE PART	GRADE P _{5d}
Both separating structure and insulation are combustible	0
Only the insulation is combustible	2
Only the separating structure is combustible	3
Both separating structure and insulation are non- combustible	5

(Minimum grade = 0 and maximum grade = 5)

PARAMETER GRADE:

$$P_5 = (0.35 \times P_{5a} \text{ Integrity and insulation} + 0.28 \times P_{5b} \text{ Firestops} + 0.24 \times P_{5c} \text{ Penetrations} + 0.13 \times P_{5d} \text{ Combustibility})$$

Note: If grade for penetrations = 0, then the parameter grade $P_5 = 0$

Resulting grade:

Comments from users: Some users have had constructions that are made up of timber studs, combustible insulation and gypsum board, and have asked how the separating structure should be graded. Since the insulation is combustible the grade 2 is recommended.

P₆ DOORS

DEFINITION: Fire separating function of doors between fire compartments

SUB-PARAMETERS:

P_{6a} Doors leading to escape route

Integrity and insulation (= EI)

(A = EI < EI 15, B = EI 15 ≤ EI < EI 30, C = EI 30 ≤ EI < EI 60, D = EI ≥ EI 60)

Type of closing (M = manually, S = self-closing)

SURVEY ITEMS	DECISION RULES							
Integrity and insulation	A	A	B	B	C	C	D	D
Type of closing	M	S	M	S	M	S	M	S
GRADE P_{6a}	0	1	1	3	2	4	3	5

(Minimum grade = 0 and maximum grade = 5)

P_{6b} Doors in escape route

Integrity and insulation (= EI)

(A = EI < EI 15, B = EI 15 ≤ EI < EI 30, C = EI 30 ≤ EI < EI 60, D = EI ≥ EI 60)

Type of closing (M = manually, S = self-closing)

If no doors are needed in the escape routes the highest grade is received.

SURVEY ITEMS	DECISION RULES								
Integrity and insulation	A	A	B	B	C	C	D	D	-
Type of closing	M	S	M	S	M	S	M	S	-
GRADE P_{6b}	0	1	1	3	2	4	3	5	5

(Minimum grade = 0 and maximum grade = 5)

PARAMETER GRADE:

$$P_6 = (0.67 \times P_{6a} \text{ Doors leading to escape route} + 0.33 \times P_{6b} \text{ Doors in escape route})$$

Resulting grade:

Comments from users: Some users have asked if a lift-door should be counted as a door in the escape route. Where the elevator is used as an escape route (with the very special requirements that need to be fulfilled for the authorities to accept such a solution), the elevator door should be counted as a door in the escape route.


P₇ WINDOWS

DEFINITION: Windows (and other facade openings) and protection of these, ie. factors affecting the possibility of fire spread through the openings

SUB-PARAMETERS:

P_{7a} Relative vertical distance

This is defined as the height of the window divided by the vertical distance between windows



Relative vertical distance, $r = l/h$

(A = $r < 1$, B = $r \geq 1$)

P_{7b} Class of window

(C = window class < E 15, D = window class \geq E 15, E = tested special design solution e.g. automatic closing shield, or window class \geq E 30)

PARAMETER GRADE P₇:

SUB-PARAMETERS	DECISION RULES					
P _{7a} Relative vertical distance	A	A	A	B	B	B
P _{7b} Class of window	C	D	E	C	D	E
GRADE P₇	0	3	5	2	5	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: Some users have commented that the relative vertical distance between windows can vary. Again, a reasonable engineering estimate should be used here. If, for example, all windows have the same relative vertical distance except two windows on the gable, the first mentioned windows should form a basis for giving the grade. A simple sensitivity analysis can then be made, where the two gable windows form a basis for the grade, to see if this influence is of any significance at all. In most cases, it will be of little significance and the problem of different relative vertical distances not of a great importance.

P₈ FACADES

DEFINITION: Facade material and factors affecting the possibility of fire spread along the facade

SUB-PARAMETERS:

P_{8a} Combustible part of facade

COMBUSTIBLE PART	GRADE P _{8a}
> 40 %	0
20 – 40 %	2
< 20 %	3
0 %	5

(Minimum grade = 0 and maximum grade = 5)

P_{8b} Combustible material above windows

COMBUSTIBLE MATERIAL ABOVE WINDOWS?	GRADE P _{8b}
Yes	0
No	5

(Minimum grade = 0 and maximum grade = 5)

P_{8c} Void

Does there exist a continuous void between the facade material and the supporting wall?

TYPE OF VOID	GRADE P _{8c}
Continuous void in combustible facade	0
Void with special design solution for preventing fire spread	3
No void	5

PARAMETER GRADE:

$P_8 = (0.41 \times P_{8a} \text{ Combustible part of facade} + 0.30 \times P_{8b} \text{ Combustible material above windows} + 0.29 \times P_{8c} \text{ Void})$

Resulting grade:

Comments from users: The first sub-parameter does not differentiate between different materials, such as fire-impregnated wood or non-impregnated wood. These must therefore be treated equally in the present version of the index method. But the engineer and the authorities should keep this in mind when making overall decisions once the index has been calculated. Also the combustible part of the facade can differ on different facades; one facade may have > 40% combustible material while another facade has < 20%. A "reasonable worst case" engineering estimate should be made, in this case the facade that has >40% combustible material should be deemed to be representative. Also, in buildings with external walkways (meaning that the exit from each apartment leads to an outside balcony and a stairway from there to the ground level), flame spread is relatively unlikely across the external gallery and up the rest of the facade. The combustible part of the wall should therefore be significantly reduced when grading buildings with external walkways.

P₉ ATTIC

DEFINITION: Prevention of fire spread to and in attic

SUB-PARAMETERS:

P_{9a} Prevention of fire spread to attic (eg. is the design such that ventilation of the attic is not provided at the eave? The most common mode of exterior fire spread to the attic is through the eave. Special ventilation solutions avoid this.)

N	No
Y	Yes

P_{9b} Fire separation in attic (ie. extent to which the attic area is separated into fire compartments)

MAXIMUM AREA OF FIRE COMPARTMENT IN ATTIC	GRADE P _{9b}
No attic	H
< 100 m ²	M
100 – 300 m ²	L
300 – 600 m ²	L
> 600 m ²	N

(N = no grade, L = low grade, M = medium grade and H = high grade)

PARAMETER GRADE P_{9a}:

SUB-PARAMETERS	DECISION RULES							
P _{9a} Prevention of fire spread to attic	N	N	N	N	Y	Y	Y	Y
P _{9b} Fire separation in attic	N	L	M	H	N	L	M	H
GRADE P₉	0	1	2	5	2	3	4	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: This parameter could be further differentiated, giving an extra grade if the attic is separated at the boundaries of each apartment. In that case only one apartment would be adjacent to each fire compartment in the attic. The Project group considered this but found that this differentiation might be too detailed and might increase complexity. The user may therefore increase the grade by one unit (maximally up to grade 5), if the attic is separated at each apartment boundary, using this comment as argument.

P₁₀ ADJACENT BUILDINGS

DEFINITION: Minimum separation distance from other buildings. If the buildings are separated by a fire wall this is deemed to be equivalent to 8 m distance.

PARAMETER GRADE P₁₀:

DISTANCE TO ADJACENT BUILDING, D	GRADE P ₁₀
$D < 6 \text{ m}$	0
$6 \leq D < 8 \text{ m}$	1
$8 \leq D < 12 \text{ m}$	2
$12 \leq D < 20 \text{ m}$	3
$D \geq 20 \text{ m}$	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: No comments yet.

P₁₁ SMOKE CONTROL SYSTEM

DEFINITION: Equipment and systems in escape routes for limiting spread of toxic fire products

SUB-PARAMETERS:

P_{11a} Activation of smoke control system

N	No smoke control system
M	Manually
A	Automatically

P_{11b} Type of smoke control system

N	Natural ventilation through openings near ceiling
M	Mechanical ventilation
PN	Pressurisation and natural ventilation for exiting smoke
PM	Pressurisation and mechanical ventilation for exiting smoke

PARAMETER GRADE P₁₁:

SUB-PARAMETERS	DECISION RULES									
P _{11a} Activation of smoke control system	N	M	M	M	M	A	A	A	A	A
P _{11b} Smoke vent openings	-	N	M	PN	PM	N	M	PN	PM	PM
GRADE P₁₁	0	2	2	3	3	4	4	5	5	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: A very misleading grade is received if the building has external walkways (meaning that the exit from each apartment leads to an outside balcony and a stairway from there to the ground level). For many such buildings no smoke control system is needed since the smoke flows freely from the walkway to the atmosphere. In some such buildings, however, skirting boards may divide the walkway from the atmosphere, creating a smoke reservoir in the walkway. Engineering estimates must therefore be used for buildings with external walkways when grading this parameter.

P₁₂ DETECTION SYSTEM

DEFINITION: Equipment and systems for detecting fires

SUB-PARAMETERS:

P_{12a} Amount of detectors

Detectors in apartment (N = none, A = at least one in every apartment, R = more than one in every apartment)

Detectors in escape route (N = no, Y = yes)

SURVEY ITEMS	DECISION RULES					
Detectors in apartment	N	N	A	R	A	R
Detectors in escape route	N	Y	N	N	Y	Y
GRADE P_{12a}	N	L	L	M	H	H

(N = no grade, L = low grade, M = medium grade and H = high grade)

P_{12b} Reliability of detectors

Detector type (H = heat detectors, S = smoke detectors)

Detector power supply (B = battery, P = power grid, BP = power grid and battery backup)

SURVEY ITEMS	DECISION RULES					
Detector type	H	H	H	S	S	S
Detector power supply	B	P	BP	B	P	BP
GRADE P_{12b}	L	M	M	M	H	H

(N = no grade, L = low grade, M = medium grade and H = high grade)

PARAMETER GRADE P₁₂:

SUB-PARAMETERS	DECISION RULES									
P _{12a} Amount of detectors	N	L	L	L	M	M	M	H	H	H
P _{12b} Reliability of detectors	-	L	M	H	L	M	H	L	M	H
GRADE P₁₂	0	1	2	2	2	3	3	3	4	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: No choice is available for combined smoke and heat detectors. The Project group recommends that the sub-parameter "Reliability of detectors" receive the grade "H" if there is a combination of heat and smoke detectors in the building.

P₁₃ SIGNAL SYSTEM

DEFINITION: Equipment and systems for transmitting an alarm of fire

SUB-PARAMETERS:

P_{13a} Type of signal

Light signal (N = no, Y = yes)

Sound signal (N = no, A = alarm bell, S = spoken message)

SURVEY ITEMS	DECISION RULES					
Light signal	N	Y	N	N	Y	Y
Sound signal	N	N	A	S	A	S
GRADE	N	L	M	H	M	H

(N = no grade, L = low grade, M = medium grade and H = high grade)

P_{13b} Location of signal

Do you just receive a signal within the fire compartmentation or is it also possible to warn other occupants?

A	The signal is sent to the compartment only.
B	It is possible to send a signal manually to the whole building or at least to a large section of the building.

PARAMETER GRADE P₁₃:

SUB-PARAMETERS	DECISION RULES						
P _{13a} Type of signal	N	L	L	M	M	H	H
P _{13b} Location of signal	-	A	B	A	B	A	B
GRADE P₁₃	0	1	2	3	4	4	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: In a test of the method, when several different users graded several different buildings, it was found that some users considered a simple smoke detector to be a part of a signal system and other users gave the grade 0 for the signal from a single smoke or heat detector. When analysing the results, it was found that if individual smoke detectors were to be given a grade as a signal system, then an elaborate signal system would get hardly any advantage over a single smoke detector. It is therefore advised that the grade 0 be given if the signal is from individual detectors, but grades be given in an ordinary way for detectors that are interconnected or arranged in a system of some sort.

P₁₄ ESCAPE ROUTES

DEFINITION: Adequacy and reliability of escape routes

SUB-PARAMETERS:

P_{14a} Type of escape routes

Staircase (A = one staircase may be used as an escape route, B = escape route leading to two independent staircases, C = direct escape to two independent staircases).

Window/Balcony (D = windows and balconies can not be used as escape routes, E = one window may be used as an escape route, F = at least two independent windows may be used as escape routes, G = the balcony may be used as an escape route, H = at least one window and the balcony may be used as escape routes)

SURVEY ITEMS	DECISION RULES											
Staircase	A	A	A	A	B	B	B	B	C	C	C	C
Window/Balcony	E	F	G	H	E	F	G	H	D	E	F	G
GRADE P_{14a}	0	1	1	3	2	3	3	4	4	5	5	5

(Minimum grade = 0 and maximum grade = 5)

P_{14b} Dimensions and layout

Maximum travel distance to an escape route (A < 10 m, B = 10 – 20 m, C > 20 m)

Number of floors (D ≤ 4, E = 5 – 8)

Maximum number of apartments per floor connected to an escape route (F ≤ 4, G ≥ 5)

SURVEY ITEMS	DECISION RULES											
Travel distance to...	C	C	C	C	B	B	B	B	A	A	A	A
Number of floors	E	E	D	D	E	E	D	D	E	E	D	D
Number of apartments...	G	F	G	F	G	F	G	F	G	F	G	F
GRADE P_{14b}	0	1	2	2	3	3	4	4	4	4	5	5

(Minimum grade = 0 and maximum grade = 5)

P_{14c} Equipment

Guidance signs (A = none, B = normal, C = illuminating light), General lighting (D = manually switched on, E = always on)

Emergency lighting (F = not provided, G = provided)

SURVEY ITEMS	DECISION RULES											
Guidance signs	A	A	A	A	B	B	B	B	C	C	C	C
General lighting	D	D	E	E	D	D	E	E	D	D	E	E
Emergency lighting	F	G	F	G	F	G	F	G	F	G	F	G
GRADE P_{14c}	0	3	3	4	2	4	3	4	2	4	3	5

(Minimum grade = 0 and maximum grade = 5)

P_{14d} Linings and floorings

This refers to the worst lining or flooring class that is to be found in an escape route (excluding the small amounts allowed by building law. The flooring must have at least class D_{FL} which is fulfilled by e.g. solid timber floor.

Typical products	LINING CLASS					GRADE P _{14d}
	Possible Euroclass *	DK	FIN	NO	SWE	
Stone, concrete	A1	A	1/I	ln1	I	5
Gypsum boards	A2	A	1/I	ln1	I	5
Best FR woods (impregnated)	B	A	1/I	ln1	I	4
Textile wall cover on gypsum board	C		1/II 2/-	ln2	II	3
Wood (untreated)	D	B	1/-	ln2	III	2
Low density wood fibreboard	E	U	U	U	U	1
Some plastics	F	U	U	U	U	0

(Minimum grade = 0 and maximum grade = 5); * Only main class given

PARAMETER GRADE:

P₁₄ = (0.34 × P_{14a} Type of escape routes + 0.27 × P_{14b} Dimensions and layout + 0.16 × P_{14d} Linings and floorings + 0.23 × P_{14c} Equipment)

Resulting grade:

Comments from users: There is no provision for buildings with external walkways (meaning that the exit from each apartment leads to an outside balcony and a stairway from there to ground level). The first parameter should reflect this by assuming that escape is also possible from a balcony. When the building has external walkways the grade for parameter P_{14b} should be 4 (= B, D, E) for buildings with ≤ 4 floors and should be 3 (= B, E, F) for buildings with 5 – 8 floors. Also, sometimes motion detectors turn on the light automatically. These should be graded as if the light were always switched on. Finally, no account is taken of the type of floor material in escape routes.

P₁₅ STRUCTURE - LOAD-BEARING

DEFINITION: Structural stability of the building when exposed to a fire

SUB-PARAMETERS:

P_{15a} Load-bearing capacity

LOAD BEARING CAPACITY (LBC)	GRADE P _{15a}
LBC < R 30	0
R 30 ≤ LBC < R 60	2
R 60 ≤ LBC < R 90	4
R 90 ≤ LBC	5

(Minimum grade = 0 and maximum grade = 5)

P_{15b} Combustibility

Combustible part of the load-bearing construction

COMBUSTIBLE PART	GRADE P _{15b}
Both load-bearing structure and insulation are combustible	0
Only the insulation is combustible	2
Only the load-bearing structure is combustible	3
Both load-bearing structure and insulation are non- combustible	5

(Minimum grade = 0 and maximum grade = 5)

PARAMETER GRADE:

$$P_{15} = (0.74 \times P_{15a} \text{ Load-bearing capacity} + 0.26 \times P_{15b} \text{ Combustibility})$$

Resulting grade:

Comments from users: No comments yet.

P₁₆ MAINTENANCE AND INFORMATION

DEFINITION: Inspection and maintenance of fire safety equipment, escape routes etc. and information to occupants on suppression and evacuation

SUB-PARAMETERS:

P_{16a} Maintenance of fire safety systems ie. detection, alarm, suppression and smoke control system

MAINTENANCE OF FIRE SAFETY SYSTEMS	GRADE P _{16a}
Carried out less than every three years	0
Carried out at least once every three years	2
Carried out at least once a year	4
Carried out at least twice a year	5

(Minimum grade = 0 and maximum grade = 5)

P_{16b} Inspection of escape routes

INSPECTION OF ESCAPE ROUTES	GRADE P _{16b}
Carried out less than every three years	0
Carried out at least once a year	1
Carried out at least once every three months	3
Carried out at least once per month	5

(Minimum grade = 0 and maximum grade = 5)

P_{16c} Information to occupants on suppression and evacuation

Written information (A = no information, B = written information on evacuation and suppression available in a prominent place in the building, C = written information available in a prominent place and distributed to new inhabitants)

Drills (D = no drills, E = suppression drill carried out regularly, F = evacuation drill carried out regularly, G = suppression and evacuation drills carried out regularly)

SURVEY ITEMS	DECISION RULES											
Written information	A	A	A	A	B	B	B	B	C	C	C	C
Drills	D	E	F	G	D	E	F	G	D	E	F	G
GRADE P _{16c}	0	1	1	2	1	3	3	4	2	4	4	5

(Minimum grade = 0 and maximum grade = 5)

PARAMETER GRADE:

P₁₆ = (0.40 × P_{16a} Maintenance of fire safety systems + 0.27 × P_{16b} Inspection of escape routes + 0.33 × P_{16c} Information)

Resulting grade:

Comments from users: A repeatability study of the method has shown that there is some variance in this parameter when different engineers judge the same building. This is because design drawings and documentation give very little information on this parameter. There is no doubt, however, that maintenance and information are a very important fire risk parameter. The user is therefore advised to make an effort to seek information from other sources in order to make a reasonable estimate of this parameter.

P₁₇ VENTILATION SYSTEM

DEFINITION: Extent to which the spread of smoke through the ventilation system is prevented.

PARAMETER GRADE P₁₇:

TYPE OF VENTILATION SYSTEM	GRADE P₁₇
No specific smoke spread prevention through the ventilation system	0
Central ventilation system, designed to let smoke more easily into the external air duct than ducts leading to other fire compartments. The ratio between pressure drops in these ducts is in the order of 5:1	2
Ventilation system specially designed to be in operation under fire conditions with sufficient capacity to hinder smoke spread to other fire compartments	3
Ventilation system with a non-return damper, or a smoke detector controlled fire gas damper, in ducts serving each fire compartment.	4
Individual ventilation system for each fire compartment	5

(Minimum grade = 0 and maximum grade = 5)

Resulting grade:

Comments from users: No comments yet

PARAMETER SUMMARY TABLE

Fire Risk Index Method – Multi storey Apartment Buildings: Version 2.0

Grades for each parameter has to be inserted in the Summary table below and multiplied by the weight. Maximum individual grade for each parameter is 5.00. The weights have been developed by the Delphi panel³. The weighted grades for all parameters are then summed and result in a score with a maximum value of 5.00.

The Risk Index is defined as $5 - \text{Score}$. A low Risk Index means low risk and high fire safety level in the same way as other risk assessment methods⁴.

Summary table

Parameter	Weight	Grade	WEIGHTED GRADE
P ₁ Linings in apartment	0.0576		
P ₂ Suppression system	0.0668		
P ₃ Fire service	0.0681		
P ₄ Compartmentation	0.0666		
P ₅ Structure - separating	0.0675		
P ₆ Doors	0.0698		
P ₇ Windows	0.0473		
P ₈ Facades	0.0492		
P ₉ Attic	0.0515		
P ₁₀ Adjacent buildings	0.0396		
P ₁₁ Smoke control system	0.0609		
P ₁₂ Detection system	0.0630		
P ₁₃ Signal system	0.0512		
P ₁₄ Escape routes	0.0620		
P ₁₅ Structure – load-bearing	0.0630		
P ₁₆ Maintenance and information	0.0601		
P ₁₇ Ventilation system	0.0558		
Sum	1.0000		
SCORE (Sum of weighted grades)			→

RISK INDEX (= 5 – Score)	→
--------------------------	---

This summary table is also available at Internet, <http://www.brand.lth.se/frim-mab>, for automatic calculation of the Risk Index from input data for a building.

REFERENCES

1. Östman B, König J, Mikkola M, Stenstad V, Carlsson J, Karlsson B: *Brandsäkra trähus , VERSION 2 – Nordisk kunskapsöversikt och vägledning (in Swedish)* ("Fire Safe Timber Buildings – Knowledge Review and Guidelines "), Publication Nr 0210034, Trätek, Swedish Institute for Wood Technology Research, 2002
2. Larsson D: *Developing the Structure of a Fire Risk Index Method for Multistorey Apartment Buildings*, Report 5062, Department of Fire Safety Engineering, Lund University, 2000.
3. Karlsson B, Larsson D: *Using a Delphi Panel for Developing a Fire Risk Index Method for Multistorey Apartment Buildings*, Report 3114, Department of Fire Safety Engineering, Lund University, 2000.
4. Hultquist H, Karlsson B: *Evaluation of a Fire Risk Index Method for Multistorey Apartment Buildings*, Report 3088, Department of Fire Safety Engineering, Lund University, 2000.
5. Christensson A: *Kravnivåer till indexmetod för bedömning av brandrisker i flervånings bostadshus (in Swedish)* ("Limiting risk index for FRIM-MAB"), Report 5095, Department of Fire Safety Engineering, Lund University, 2002.
6. Christensson A, Karlsson B: *Repeatability of FRIM-MAB Fire Risk Index Method for Multistorey Apartment Buildings*, Trätek Rapport P 0212052, 2002.
7. Karlsson B, Östman B: *Brandrisker i flervånings bostadshus – Indexmetoden Version 2.0 (in Swedish)*, Kontenta 0009024 Revised 2002, Trätek, Swedish Institute for Wood Technology Research, 2002.

Detta digitala dokument
skapades med anslag från
**Stiftelsen Nils och Dorthi
Troëdssons forskningsfond**

Trätek

INSTITUTET FÖR TRÄTEKNISK FORSKNING

Box 5609, 114 86 STOCKHOLM
Besöksadress: Drottning Kristinas väg 67
Telefon: 08-762 18 00
Telefax: 08-762 18 01

Vidéum Science Park, 351 96 VÄXJÖ
Besöksadress: Lückligns plats 1
Telefon: 0470-59 97 00
Telefax: 0470-59 97 01

Skeria 2, 931 77 SKELLEFTEÅ
Besöksadress: Laboratorgränd 2
Telefon: 0910-28 56 00
Telefax: 0910-28 56 01